A Smart Monitoring System for Preventing Gas Risks in Indoor

Gyoutae Park, Geunjun Lyu, Yeonjae Lee, Wooksuk Kim, Jaheon Gu, Sanguk Ahn, Hiesik Kim

Abstract—In this paper, we propose a system for preventing gas risks through the use of wireless communication modules and intelligent gas safety appliances. Our system configuration consists of an automatic extinguishing system, detectors, a wall-pad, and a microcomputer controlled micom gas meter to monitor gas flow and pressure as well as the occurrence of earthquakes. The automatic fire extinguishing system checks for both combustible gaseous leaks and monitors the environmental temperature, while the detector array measures smoke and CO gas concentrations. Depending on detected conditions, the micom gas meter cuts off an inner valve and generates a warning, the automatic fire-extinguishing system cuts off an external valve and sprays extinguishing materials, or the sensors generate signals and take further action when smoke or CO are detected. Information on intelligent measures taken by the gas safety appliances and sensors are transmitted to the wall-pad, which in turn relays this as real time data to a server that can be monitored via an external network (BcN) connection to a web or mobile application for the management of gas safety. To validate this smart-home gas management system, we field-tested its suitability for use in Korean apartments under several

Keywords—Gas sensor, leak, gas safety, gas meter, gas risk, wireless communication.

I. INTRODUCTION

To ensure occupant comfort and safety, modern, high-end houses and apartments built in Korea are increasingly being equipped with sensor-based devices to monitor and regulate gas, electricity, and water facilities, a trend that will surely continue to produce improved monitoring systems [1]. The evolution of ubiquitous wireless sensor networks (USNs) has fostered the development of "smart environments" in which numerous sensor nodes are embedded in streets, houses, buildings, and automobiles [2]. One component of the smart environment—the automatic meter reader (AMR)—is designed to deliver total monthly usage data, but it can also gather detailed usage information, automatically detect leaks and equipment problems, and aid in tamper detection [3]. Several gas safety management systems incorporating intelligent multi-function gas meters based on ZigBee network technology, automatic gas leak cutoffs, and smoke, methane, and

Gyoutae Park is with the Institute of Gas R&D Center, Korea Gas Safety Corporation, Chung-buk Korea (corresponding author to provide phone: +82-10-2677-1336; fax: +82-43-750-1948; e-mail: gtparkgs@kgs.or.kr).

Geunjun Lyu, Yeonjae Lee, and Woosuk Kim are with the Institute of Gas R&D, Korea Gas Safety Corporation, Chung-buk Korea(e-mail: gjlyu@kgs.or.kr, lyj@kgs.or.kr, kws1004@kgs.or.kr).

Jaheon Gu is with J2plus. Co., Ltd., Gyeonggi-do Korea (e-mail: jaheon@j2plus.co.kr).

Sangguk Ahn is with RFengine. Co., Ltd., Gyeonggi-do Korea (e-mail: sgahn@rfengine.co.kr).

temperature detectors have been proposed by the authors, who, in conjunction with other researchers, also pioneered in the development of the micom gas meter—an intelligent microcomputer controlled gas meter—with a built-in cutoff valve and sensors for detecting flow, pressure, and seismic events [4]. If the micom gas meter detects an abnormal state with respect to any of these factors, it uses an inner valve to shut off gas flow and then delivers a user warn [5]. In addition, an external gas valve can be cut off if the monitored temperature surpasses 100°C or if a gas (methane or CO) leakage or fire is detected at either the gas pipeline or the facilities. The safety management systems developed in these studies have fabricated using CC2430 and EM250 ZigBee chips with ZigBee Pro stacks [6], [7].

In this study, we designed a new gas safety management system (GSMS) based on a JN5139 ZigBee wireless networking solution and tested it under various scenarios. Our system is an automatic fire-extinguishing system (AFES) with a star topology centered on a micom gas meter and a smoke and CO detector [8]. The AFES serves as a router to deliver safety and risk signals to a wall-pad that functions as a ZigBee network gateway, and if an abnormal state occurs at each sensor node, the system takes preventative safety measures and then informs safety managers and users that a risk situation has occurred [9]. The embedding ability of this system into the "internet of things" and its connectivity to smart device networks in homes and other buildings was demonstrated through field testing.

II. DEVELOPMENT OF A SMART MONITORING SYSTEM

A. Wireless Communication Modules

Fig. 1 shows a wireless module based on Jennic's JN5139 wireless microcontroller. These modules are used in our system both as wall-pad sink nodes and as sensor nodes for the micom gas meters, automatic fire-extinguishing system—which serves as a router—and the smoke and CO detector.




Fig. 1 Wireless modules with JN5139 microcontroller

The monitoring devices use JN5139 microcontrollers that are both ZigBee and standard IEEE802.15.4 2.4 GHz-compatible,

with 16 MHz, 32-bit RISC CPUs and 96 and 192 kB of RAM and ROM, respectively, along with four-input 12-bit analog-to digital converters (ADCs), two 11-bit digital-to-analog convertors (DACs), two comparators, a temperature sensor, two universal asynchronous receiver-transmitters (UARTs), and two-wire serial interfaces [10].

B. Intelligent Micom Gas Meters

The intelligent micom gas meter—a variant of a standard gas meter with a built-in microcontroller and a cutoff valve-not only measures gas flow and pressure but can also monitor earthquake activity. The meter can open and close an inner cutoff valve and deliver a warning to users if abnormal measurements of gas or seismic activity occur in a gas facility or house. Fig. 2 explains the components and functions of an intelligent micom gas meter incorporating a wireless communication module (cyan color) with a JN5139 microcontroller. The meter classifies flow measurements as massive, cumulative, instantaneously rising, or descending, while pressure measurements can be high or low. The earthquake function with associated alarm buzzer is triggered by an event of magnitude 3.0 or higher on the Richter scale. Two of the micom gas meter external ports are connected to add gas detectors and sensors that deliver signals for gauging gas safety states in specific sectors. Table I shows the safety functions of the micom gas meter, including automatic control and shut-off.




Fig. 2 Components and functions of micom gas meter with wireless module

TABLE I FUNCTIONS OF AN INTELLIGENT MICOM GAS METER

No.	Functions	No.	Functions		
1	Mass flow rate (m ³ /h)	7	Set upper pressure (mmH ₂ O)		
2	Cumulative flow rate (m ³ /h)	8	Set lower pressure (mmH ₂ O)		
3	Instantaneous rising flow rate (m³/h)	9	Determine continuous use time (min)		
4	Instantaneous descending flow rate(m³/h)	10	Open/Close cutoff valve		
5	Infinitesimal flow rate (m³/h)	11	Check cutoff valve		
6	Current pressure (mmH ₂ O)	12	Management codes, alarm and buzzer activation		

C. Automatic Fire Extinguishing Systems

Fig. 3 shows an automatic fire extinguishing system (AFES) controller with a wireless module, and Fig. 4 shows the AFES in its connected configuration for detecting gas leaks and abnormal temperatures. In the event that a risk signal is received from a gas leak detector, or if the temperature sensor indicates temperatures above 100°C, the AFES controller closes a shut-off valve; if the temperature reaches 130°C, the controller induces the fire extinguishing system to spray suppressing chemicals when the temperature goes up over 130°C for at least one minute. To detect combustible gas, the detector system outputs at 12 V.



Fig. 3 Interior of AFES controller with wireless module




Fig. 4 Diagram of connected AFES configuration

D.Smoke and CO Detectors



Fig. 5 CO and smoke detector with wireless module

Fig. 5 shows a smoke and carbon monoxide (CO) detector with a wireless module; when a fire occurs, the detector sends an event signal to a wall-pad via the automatic fire extinguishing system receiver. The CO monitoring

functionality is useful in gas boilers, where incomplete combustion of fuel produces toxic carbon monoxide; if CO gas is detected, The CO sensor sends a risk signal to the wall-pad via the automatic fire extinguishing system receiver, while smoke levels are monitored to determine if a fire is occurring.

E. A Wall-pad with Wireless Modules



Fig. 6 Front and rear sides of a wall-pad with wireless module

Fig. 6 shows the front and rear sides of a wall-pad equipped with a wireless communication module. The wall-pad contains is controlled by an embedded Windows XP Pro operating system, features an 8.4-in LCD panel and an Atom N270 1.6G Hz CPU, and has 1 GB of DDR2 RAM, a SATA 160 GB hard disk drive (HDD), and USB-type wireless Ethernet LAN connectivity. In order to test the wall-pad application program, we implemented several gas safety management scenarios using Microsoft Visual Studio 2010. In the simulations, the wall-pad received gas flow, pipeline pressure, and earthquake-related data through a micom gas meter, and gas leaks or temperatures in the range of 100 to 130°C were signaled by an automatic fire extinguishing system consisting of a smoke sensor and CO detector.



Fig. 7 Experimental pilot setup consisting of gas safety appliances and wall-pad

If an abnormal state occurred in all gas safety appliances, the wall-pad took emergency action and then delivered the relevant signals and state data to the web via a mobile server. Fig. 7 shows an assembled gas safety system consisting of appliances and wall-pad controllers; using this, we conducted a pilot experiment in which the gas safety appliances and wall-pad controller were subjected to various scenario conditions.

F. Smart Monitoring System for Preventing Gas Risks

PROTOCOL AND BAUD RATES OF DEVICES AND NODES				
Devices	Protocol	Nodes/Connection		
Micom-gas-meters	RS-232 (9,600bps)	Sensor nodes		
CO detectors	RS-232 (9,600bps)	Sensor nodes		
Smoke detectors	RS-232 (9,600bps)	Sensor nodes		
Automatic fire-extinguishing	RS-232	Sensor nodes,		
system	(19,200bps)	Routers		
Wall-pads	RS-232 (9,600bps)	Sink nodes		
A wall-pad ↔ a USB port	RS-232	Internal		
A wan-pad ↔ a USB port	(38,400bps)	connections		
Wall-pads ↔ a server	WLAN(54 Mbps) BcN (100Mbps)	Wireless and wired Networks		

Table II shows the communication protocols and baud rates of the devices used to effect gas safety management system interconnection, and Fig. 8 shows both wired (solid lines) and wireless (dotted lines) signal flow in the system. The wireless sensor network is configured by classifying the sensor nodes as, variously, micom gas meters, automatic fire-extinguishing system, smoke and CO detectors, or sink nodes (e.g., wall-pads), and inner protocols are interfaced between the nodes and appliances. The diagram shows the signaling stream directions used to manage the system through a web site; in this case, a smart phone network controls the gas safety appliances via internet and mobile connectivity. Through the internet gateway, the smart phone application sends ZigBee commands to the management system, which in turn relays these commands into the JenNet (JN5139) wireless network. A wireless microcontroller on each network gas safety appliance runs an application to interpret the ZigBee commands in order to control the appliance and monitor the gas safety state.




Fig. 8 Network configuration of the smart monitoring system

Users can connect to a smart monitoring system server through either the web or a mobile site at any time or place in order to inspect and manage system operation. As described previously, an internal valve within the micom gas meter will close if it receives abnormal information from the gas flow, pipeline pressure, or earthquake sensors, while the automatic fire extinguishing system will close an external valve if it receives a gas leak reading or detects temperatures above 100°C.

If smoke and CO are detected together, both the gas meter internal valve and the external valve are closed.

Following the configuration shown in Fig. 9, we installed a smart monitoring system for gas safety in an apartment building with the server located in the apartment management office. Based on data provided by the gas safety devices, this system is able to independently implement the security steps described above and then notify users, safety managers, gas suppliers, and governing bodies via the management server in the event of gas leakage or abnormalities in terms of pressure, flow, or seismic conditions. Table III lists the test scenarios and procedures for gas safety management used by the devices, and Fig. 9 shows a schematic diagram of the safety appliances, wall-pad, routing technology, and wireless web server—an ML350G6 HP server with a Xeon E5504 processor that configures the web and mobile sites using MS SQL 2008MS hosted on a Windows7 operating system.




Fig. 9 Signal Flow of a Smart Monitoring System

TABLE III SCENARIOS OF SMART MONITORING SYSTEM

SCENARIOS OF SMART MONITORING SYSTEM				
N	Appliances	Scenarios and procedures		
1 Micom gas meter		 Structure: built-in sensors (pressure, flow rate, seismic scope, and inner gas valve) Monitors: gas pressure, flow rate at pipelines, and seismic activity 		
2	Automatic fire extinguishing System	 Operation: generates alarm, shuts off of inner valve Monitors: detect combustible gas leakage and dangerous temperatures (i.e., between 100 and 130 °C) Operation: Operation: Generate alarm, shut off external gas valve for gas leak or temperature above 100 °C. Close inner valve in micom gas meter. Spray fire-extinguishing chemicals at temperatures above 130 °C 		
3	Smoke sensor	- Monitors : smoke - Operation : After generating alarm, closes inner valve in micom gas meter and then stops boiler system		
4	CO sensor	Monitor: carbon dioxide gas Operation: After generating alarm, closes inner valve in micom gas meter and then stops boiler		

III. EXPERIMENTAL RESULTS

We manufactured a test-bed shown in Fig. 10 on which to assess the performance of the S-GSMS when subjected to the scenarios shown in Table III. Table IV is part names in Fig. 10

Before field testing and application of this setup, we carried out enough experiments using air instead of gas in which the air pressure was lowered using primary and secondary pressure regulators by two orders of magnitude to about 2.8 kPa, which is approximately the pressure in a working gas pipeline. The items and parameters tested included wireless communication operation, control of the wall-pad, pressure levels, gas use response, seismic measurements, gas leakage, temperature, and levels of smoke and CO detected.





Fig. 10 Test-bed for experimentally assessing SMS

TABLE IV TEST-BED ELEMENTS

- 1. Primary Pressure Regulator 7. Automatic fire extinguishing system operator 2. Secondary Pressure Regulator 8. Fire extinguishing materials Regulator 9. Temperature sensor 4. Micom gas meter 9. Temperature sensor 5. Middle shut-off valve 5. Middle shut-off valve 5. Carbon monoxide (CO) sensor 6. Automatic fire extinguishing c. Smoke sensor
- 6. Automatic fire extinguishing system receiver
- Fig. 11 shows a control flowchart of remote, web-based management of the smart gas safety monitoring system(S-GSMS). As shown in the figure, the micom gas meter decides whether the inner valve needs to be shut and then closes



or opens the valve based on measured consumption flow, gas pressure, usage time, or detection of an earthquake of

magnitude 5.0 or greater on the Richter scale.

Fig. 11 Flow chart diagram of S-GSMS accessed via web sites

The automatic fire extinguishing system, which serves as a router, opens and closes the external valve in the event of a temperature measurement above 100°C or a detected gas leak, while sensors detect smoke and carbon monoxide. The wall-pad delivers all information received from the fire extinguishing system router to the server. Based on the test results, which are discussed below, the system delivered outstanding normal processing performance when assessed against the scenarios described in Table III. Fig. 12 shows a schematic of the gas safety appliance system control and management procedure implemented in a living room and monitored on a smart phone screen through a connected mobile site. In this experimental setup, we installed realistic gas safety appliances, a wall-pad, and a server with web and mobile pages and verified that the controlled function outputs on the smart phone (Galaxy Note, Samsung CO., Ltd) coincided with those on the PC (HP Co., Ltd).




Fig. 12 Field test in a living room to verify S-GSMS operation

Fig. 13 shows a relational flow diagram model for processing the S-GSMS data in order to manage the gas safety and risk history, and Fig. 14 shows a test setup in which we used several S-GSMSs to control and manage more than 100 houses in four villages. Using this setup, a test run of the system with respect to the gas safety scenarios listed in Table III was conducted.




Fig. 13 Relational model for processing S-GSMS data



Fig. 14 Performance test of multiple monitoring systems

Table V shows the experimentally assessed response times for each S-GSMS sequence, while Table VI explains the various sequences. Fig. 15 shows data gathered in daily measurements by the micom gas meter of (1) cumulative flow rates and (2) instantaneous rising flow rates. If the cumulative flow rates exceeded a predetermined target value, the inner valve of the meter was closed. The inner valve was also closed in the event of gas pipeline cracking or overheating, as these events would cause an abrupt increase in the instantaneous flow rate. Fig. 16 shows experimentally measuring values of gas pipeline high and low pressures respectively by the micom-gas meter. If daily measuring pressures of the inner micom-gas meter are higher and lower predetermined target values due to by fires or leakages, the inner valve of the micom-gas meter was closed.

TABLE V
RESPONSE TIMES FOR S-GSMS SAFETY MEASURES

Legend	Safety measures	Response Time (s)
A	Alarm at micom gas meter.	2
В	Shut-off of inner valve at micom gas meter. (Results in operational stop of boiler system because gas fuel supply is stopped)	10
C	Alarm in automatic fire extinguishing system.	2
D	Shut-off of external pipeline gas valve in automatic fire extinguishing system.	5
Е	Spraying of fire-extinguishing materials in automatic fire extinguishing system.	15
F	Smoke alarm in wall-pad	2
G	CO alarm in wall-pad	2
W	Event notification on web pages.	20
S	Event notification on smart phones	20

TABLE VI SEQUENCES OF S-GSMS

22(22::22:2:2:2:2:2:2:2:2:2:2:2:2:2:2:2				
N	Abnormal Event	Safety Appliances	Safety measures	
1	Flow rate, Gas pressure Earthquake, Using time Reason on shut-off v/v	Micom gas meter	A→B→W, S	
2	Leakage(LNG/LPG) Temperature (100°C)	Automatic fire extinguishing	$C \rightarrow D \rightarrow A \rightarrow W$, S	
3	Temperature (130 °C)	System Micom gas meter	$C \rightarrow D \rightarrow E \rightarrow W$, S	
4	Smoke	Micom gas meter	$F \rightarrow B \rightarrow W$, S	
5	Carbon monoxide	Micom gas meter	$G \rightarrow B \rightarrow W$, S	

World Academy of Science, Engineering and Technology International Journal of Information and Communication Engineering Vol:9, No:6, 2015




Fig. 15 Experimentally measured gas flow rates




Fig. 16 Experimentally measured gas pipeline pressure

Fig. 17 shows data gathered measurements of methane gas concentrations by automatic fire extinguishing system for 1 hour. If the gas concentration is detected of 25% LEL of methane, external pipeline gas valve is closed by control of automatic fire extinguishing system. Fig. 18 shows experimentally measured temperature by automatic fire extinguishing system for 65 minutes in inner houses. If timely measuring temperature is 100 degree due to fires, first an external gas valve is closed. If indoor temperature is 130 degree and continued while upper than 1 minute, fire extinguishing material is displayed at kitchen, houses.




Fig. 17 Experimentally measured gas concentrations




Fig. 18 Experimentally measured temperatures

IV. CONCLUSION

In this study, we developed and tested a smart monitoring system to prevent gas safety in Korean houses based on a network of gas safety appliances equipped with wireless communication modules incorporating JN5139 controller chips. We designed an S-GSMS consisting of gas safety appliances, sink nodes (e.g., wall-pads), an automatic fire-extinguishing system, and smoke and CO sensors, and tested it against various gas safety management scenarios. To implement this system, we designed and manufactured wall-pad sink nodes programmed to effect gas safety management scenarios in order to control the safety appliances. Using this system design, we configured a wireless sensor network for use in a house. To perform gas safety management, the sensor network was connected to an external network (BcN), which, in turn, was connected to both the internet and a smart phone network. Based on data on gas flow rate, pipeline pressure, detected seismic activity or gas leakage, temperature, and CO and smoke concentration, our proposed system can be used to take a variety of safety measures if an abnormal state occurs and then inform users and safety managers of the situation via smart phone messaging. Using simulation and experiment, we demonstrated that our S-GSMS can successfully prevent abrupt gas-based incidents in order to minimize damage to gas facilities or buildings. Based on the results discussed here, the proposed system can be effectively integrated into wireless and wired integrated communication networks in order to prevent dangerous gas and fire incidents.

ACKNOWLEDGMENT

This research was supported by Korea Institute for Advancement of Technology (KIAT) Research Project "Development of Smart Gas Leak Measuring Instrument and Performance Test Technology (No. R0003355) and by the Korea Research Foundation Project "Improve the Accuracy of Glucose Concentration Measurement Using Raman Spectroscopy (2013R1A1A 2063634)"

REFERENCES

 G.T. Park, Y.G. Kim, and J.R. Kwon, "Development of the Gas Safety Management System using an Intelligent Gasmeter with Wireless ZigBee network", in WASET, vol. 64, pp. 186-188, 2010.

World Academy of Science, Engineering and Technology International Journal of Information and Communication Engineering Vol:9, No:6, 2015

- [2] Keunsu Chang, Sungmuk Kang, etc., and Hoseung Kim, "Electric Field Energy Harvesting Powered Wireless Sensors for Smart Grid," Journal of Electrical Engineering & Technology, vol. 7, pp. 75-80, 2012.
- [3] Automatic Meter Reading Association(AMRA); available at www.amra-intl.org
- [4] Gyoutae Park, Jeong Rock Kwon, and San Hoon Park, "A Study on the Implementation of the System of Gas Safety using an Intelligent Gas Meter based on Ubiquitous Communication," Proceedings of The Korean Institute of Communication and Information Sciences, vol. 7A-63, pp. 452-453, 2008.
- [5] G.T. Park, Y.G. Kim, I.C. Kim, and H.S. Kim, "A Positive Study on Effective Gas Safety Management using Wireless Sensor Network", Proceedings of MIPRO 2012/MEET, vol. 38, 2012.
- [6] Gyoutae Park, Geunjun Lyu and Hiesik Kim, "A Study on the Effective Gas Safety Management Using Smart Appliances", Advanced Engineering Forum, vol. 2-3, pp. 649-654, 2012.
- [7] Shahin Farahani, "Zigbee Wireless Networks and Transceivers", Newnes, pp. 25-32, 2009.
- [8] G.T. Park, E. J. Kim and I. C. Kim, "Development and Field Test of a Smart-home Gas Safety Management System", KIGAS, vol. 16, pp. 129-136, 2012.
- [9] Aly El-Semary and Mohmed A. Azim, "New Trends in Secure Routing Protocols for Wireless Sensor Networks", Intl. Journal of Distributed Sensor Networks, 2013
- [10] Hung-Chi Chu and Yi-Ting, "An Adaptive Priority Factors Routing Mechanism for Wireless Sensor Networks", INFORMATION, vol. 16, pp. 2145-2288, 2013.



Gyoutae Park was born at Kyeong-buk Province in South Korea on March 29th, 1970. Now he earned Ph.D degree in School of Electrical and Computer Engineering at University of Seoul, Korea in 2014. He earned the B.S. and M.S. degrees in Electronic Engineering at the Yeongnam University, Gyeongsan, Korea in 1996 and 1999, respectively. He is currently a senior researcher of Electrical and Computer Engineering-based Gas Safety Facilities at Korea Gas Safety Corporation (KGS). His research interests

focus on IT convergence technology for gas safety management, solar cell/heat, new renewable energy, and infrared gas leak detectors.

Address: 1390 Wongjung-ro, Maengdong-myon, Eumsung-gun, Chungbuk-do, 369-811, Korea

E-mail: gtparkgs@kgs.or.kr



Hiesik Kim was born in 1953 in Kyoung-Ju, Korea. He received the Bachelor's degree in mechanical engineering from Seoul National University, Seoul, Korea, in 1977, a Master's degree in production engineering from the Korea Advanced Institute of Science and Technology (KAIST), Daejeon, Korea, and the Doctorate (Doktor-Ingenieur) degree in production engineering (FhG-IPA) from Stuttgart University, Stuttgart, Germany, in 1987, under the supervision of Prof. Dr.-Ing. H.-J. Warnecke. He was a

Technical Official with the Ministry of Science and Technology of the Korean Government from 1979 to 1982 and as Senior Researcher with the CAD/CAM Research Laboratory, KAIST from 1987 to 1989. Since 1989, he has been a Professor with the Department of Electrical and Computer Engineering, University of Seoul, Seoul. He was the Vice Dean with the Engineering College. His current research interests include optical measurement of geometries, applications of sensors for automation and image processing. E-mail: drhskim@uos.ac.kr.