

# The Feedback Control for Distributed Systems

Kamil Aida-zade, Cemal Ardil

**Abstract**—We study the problem of synthesis of lumped sources control for the objects with distributed parameters on the basis of continuous observation of phase state at given points of object. In the proposed approach the phase state space (phase space) is beforehand somehow partitioned at observable points into given subsets (zones). The synthesizing control actions therewith are taken from the class of piecewise constant functions. The current values of control actions are determined by the subset of phase space that contains the aggregate of current states of object at the observable points (in these states control actions take constant values). In the paper such synthesized control actions are called zone control actions. A technique to obtain optimal values of zone control actions with the use of smooth optimization methods is given. With this aim, the formulas of objective functional gradient in the space of zone control actions are obtained.

**Keywords**—Feedback control, distributed systems, smooth optimization methods, lumped control synthesis.

## I. THE FORMULATION OF THE PROBLEM OF LUMPED CONTROL SYNTHESIS

FEEDBACK control systems are selfmanaging systems organized by means of feedback control loops. To illustrate the proposed approach to the study of the problem of control synthesis in distributed systems, we consider the problem of control of heat-exchanger process. Let us describe briefly the process. A liquid goes through the heat-exchanger. The temperature of the liquid at the entry point of heat-exchanger is  $\psi_2(t)$ . The temperature of steam in the jacket is  $v(t)$ . The function  $v(t)$  is control parameter in the following problem:

$$u_t(x,t) = -a_1 u_x(x,t) - a_0 u(x,t) + a v(t), \quad x \in [0, l], \quad t \in [0, T] \quad (1)$$

$$u(x,0) = \psi_1(x) \in \Psi_1(x), \quad u(0,t) = \psi_2(t) \in \Psi_2(t). \quad (2)$$

Here  $u(x,t)$  is the temperature of the liquid,  $\Psi_1(x)$ ,  $\Psi_2(t)$  are given domains of initial and boundary conditions.

Let us suppose that there are  $L$  sensors mounted at the heat-exchanger at the points  $\tilde{x}_j \in [0, l]$ ,  $j = 1, \dots, L$ . The sensors perform on-line monitoring and reading-in of information about the temperature of liquid at these points into the process control system. This information is defined by the vector:

Kamil Aida-zade is with the Institute of Cybernetics NAS of Azerbaijan Republic, Baku, Azerbaijan.

Cemal Ardil is with the National Academy of Aviation, Baku, Azerbaijan.

$$u(\tilde{x}_j, t) = \tilde{u}_j(t), \quad j = 1, \dots, L, \quad t \in [t_0, T]$$

The problem is to determine such control function  $v(t) \in U$  with respect to current values of  $\tilde{u}_j(t)$ ,  $j = 1, \dots, L$  that minimizes the functional:

$$J(v) = \alpha \int_0^T v^2(t) dt + \int_0^l [u(x, T) - u^*(x)]^2 dx \quad (3)$$

Actually, we have to find the mean value of functional (3) for all possible initial and boundary conditions, i.e., the functional to be minimized are:

$$J(v) = \alpha \int_0^T v^2(t) dt + \int_{\Psi_1(x) \Psi_2(x)} \int_0^l \alpha_1(x) \alpha_2(x) [u(x, T; \psi_1, \psi_2, v) - u^*(x)]^2 dx d\psi_2 d\psi_1 \quad (4)$$

here  $u(x, t; \psi_1, \psi_2, v)$  is the solution of (1), (2) under specified admissible initial-boundary functions  $\psi_1(x)$ ,  $\psi_2(t)$ ; the functions  $\alpha_1(x)$ ,  $\alpha_2(t)$  are weight functions. In the case of uniform admissible initial-boundary conditions weight functions are determined as follows:

$$\alpha_1(x) = 1 / \text{mes} \Psi_1(x), \quad \alpha_2(t) = 1 / \text{mes} \Psi_2(t).$$

here  $u(x, t; \psi_1, \psi_2, v)$  is the solution of (1), (2) under specified admissible initial-boundary functions  $\psi_1(x)$ ,  $\psi_2(t)$ ; the functions  $\alpha_1(x)$ ,  $\alpha_2(t)$  are weight functions. In the case of uniform admissible initial-boundary conditions weight functions are determined as follows:

$$\alpha_1(x) = 1 / \text{mes} \Psi_1(x), \quad \alpha_2(t) = 1 / \text{mes} \Psi_2(t).$$

The condition (2) has the following meaning. During operation of heat-exchanger, current control must not "remember" exact initial-boundary conditions; conversely, the control must be tuned at their "mean" values and must depend only on the states at the observable points:

$$v(t) = v(t; \tilde{u}_1(t), \dots, \tilde{u}_L(t)). \quad (5)$$

This formulation resembles the classical one, but here we consider a more general case when  $v(t)$  can not change its value at any time instance, instead,  $v(t)$  remains constant till the values of all observable states remain in some definite zone. We suppose here that the set of all admissible values of phase variable is partitioned into zones, i.e.:

$$\underline{u} \leq u(x, t; \psi_1, \psi_2, v) \leq \bar{u}, \quad \forall(\psi_1, \psi_2, v(t)), \quad (6)$$

here  $\underline{u}, \bar{u}$  are usually known values, determined by operational consideration. Then it holds for observable states as well:

$$\underline{u} \leq \tilde{u}_j(t) \in \bar{u}, \quad j = 1, \dots, L. \quad (7)$$

Let us partition the space of observable states into intervals  $[\hat{u}_{i-1}, \hat{u}_i)$  by the values:  $\underline{u} = \hat{u}_0 < \hat{u}_1 < \dots < \hat{u}_m = \bar{u}$ . These values determine the zones of state values at the observable points. So we have:

$$\hat{u}_{i-1} \leq \tilde{u}_1(t) < \hat{u}_i, \quad \hat{u}_{i_2-1} \leq \tilde{u}_2(t) < \hat{u}_{i_2}, \dots, \hat{u}_{i_L-1} \leq \tilde{u}_L(t) < \hat{u}_{i_L}. \quad (8)$$

The sets (8) constitute  $L$ - dimensional parallelepipeds in  $L$  - dimensional phase state space  $\tilde{u}_j(t)$   $j = 1, \dots, L$ . The total number of these parallelepipeds is  $m^L$ .

It is clear that feedback with the object (i.e. sensing) is required to determine whether the state at the observable points falls into the  $(i_1, \dots, i_L)$ -th zone. The aggregate of all zones covers all possible values of observable states. It is also clear that control functions (5) change its values only at those time instants when the set of states at the observable points passes from one phase parallelepiped (8) to another one.

The problem consists in determination of constant value of  $v(t)$  for each zone while the states of all observable points remain in this zone, i.e. the following holds:

$$v(t) = v(\tilde{u}_1(t), \dots, \tilde{u}_L(t)) = v_{i_1, \dots, i_L} = const, \quad t \in [0, T] \quad (9)$$

while (8) holds.

The number of different values attained by steam temperature equals to the number of phase parallelepipeds defined by inequalities (8), i.e.,  $m^L$ . The total number of parameters to be optimized is also  $m^L$ . They determine the value of steam temperature for all possible values of liquid temperature at the observable points.

So, the considered problem of heat-exchanger process control with the use of feedback at the class of piecewise constant functions consists in optimization of  $m^L$ - dimensional vector:

$$v = (v_{\underbrace{1 \dots 1}_L}, \dots, v_{\underbrace{i_1 \dots i_L}_L}, \dots, v_{\underbrace{m \dots m}_L}) \quad (10)$$

which directly determines the course of heat-exchanger process and, consequently, the value of objective functional (11).

## II. SOLVING PROBLEM OF ZONE CONTROL SYNTHESIS

For numerical solving zone control synthesis problem, we can use the methods of finite-dimensional smooth optimization, in particular, iterative method of gradient projection type:

$$v^{(q+1)}(\alpha_q) = P_U(v^{(q)} - \alpha_q \text{grad} J(v^q)), \quad q = 0, 1, \dots, \quad (11)$$

Let us present the obtained formulas of functional gradient in the space of optimized parameters.

One of important elements in calculating gradient is the time interval when phase state  $\tilde{u}(t)$  belongs to the one or another phase parallelepiped. Let us denote by  $\Pi_{i_1, \dots, i_L}(\psi_1, \psi_2, v) \in [0, T]$  the time period during which (8) holds,  $i_1 = \overline{1, m}, \dots, i_L = \overline{1, m}$ , i.e.  $i_s = 1, \dots, m, \quad s = 1, \dots, L$  (the dependence of  $\Pi_{i_1, \dots, i_L}$  on  $\psi_1, \psi_2, v$  is evident).

In classical formulation the adjoint system with respect to  $P(x, t) = P(x, t; \psi_1, \psi_2, v)$  under fixed initial-boundary conditions and fixed control is as follows:

$$P'_t = -a_1 P'_x + a_0 P \quad (12)$$

$$P(x, T) = 2(u(x, T) - u^*(x)) \quad (13)$$

$$P(l, t) = 0. \quad (14)$$

The following theorem holds.

*Theorem 1.* The components of functional gradient in the problem (1), (2), (3) in the space of piecewise constant control actions (9) for arbitrary control  $v \in U$  under appropriate normalization are defined by the formula:

$$\frac{dJ}{dv_{i_1, \dots, i_L}} = a_0 \int \int \int_{\psi_1 \psi_2 0}^l \int_{\Pi_{i_1, \dots, i_L}} P(x, t) dt dx d\psi_2 d\psi_1 \quad (15)$$

here  $P(x, t)$  is the solution of adjoint problem (12) – (14), that corresponds to current zone control.

The formula (15) allows us to compute the functional gradient at current value of control actions and to use it further in iterative procedures of smooth optimization, for example, (11).

Let us emphasize important advantage of the proposed in the paper synthesized zone control as compared to synthesized

classical control of  $v(u(x,t))$  type. It is caused by technical complexity of on-line acquirement of information about current states of objects at the observable points and construction of control actions on the basis of this information. The construction of zone control is performed during the time when the states of object lie in the definite zones of phase space. This argues for robust features of zone control.

Also it is of practical interest to apply the proposed approach to constructing control actions from the results of observation of object current state values only at certain points of object. In many cases, this corresponds to actual capacities of measurement systems at objects.

And, finally, it is clear, that one can easily extend the study of illustrative problem of heat-exchanger control to a number of other problems of control of distributed objects, governed by functional equations of another type.

### III. NUMERICAL EXPERIMENTS

The proposed method of the considered problem solving was applied to some test problems. When executing numerical experiments, poor convergence to the solution of the problem (1-3) has been revealed. Probably, this fact is linked with the possibility of abrupt variation of  $v(t)$  when trajectory transits from one phase parallelepiped to another if the values of piece-wise constant control actions assigned to these parallelepipeds are essentially different. To overcome this, the calculations were performed in two stages. At the first stage we used a control function the value of which for a given fixed trajectory is equal to a weighted linear combination of all values of control actions for all phase parallelepipeds. The weighted coefficients for the control  $v_{i_1 \dots i_L}$  were inversely proportional to the distance from the current trajectory to the  $i_1 \dots i_L$ -th phase parallelepipeds, i.e.:

$$v_{sm}(t) = \sum_{i_1=1}^m \dots \sum_{i_L=1}^m \lambda_{i_1 \dots i_L} v_{i_1 \dots i_L}, \quad (16)$$

$\lambda_{i_1 \dots i_L} = e^{-\frac{\rho_{i_1 \dots i_L}^2}{2\sigma^2}}$ , here  $\rho_{i_1 \dots i_L}$  is the distance from trajectory  $u(x,t)$  to the  $i_1, \dots, i_L$ -th phase parallelepiped. Control in the form (16) we will call "smoothed control".

Numerical experiments were carried out for problems with different terminal function  $u^*(x)$ .

### REFERENCES

- [1] Aida-zade K.R. The problem of control in the mean with respect to regional control actions. Transactions of the National Academy of Sciences of Azerbaijan, №4, 2003.
- [2] Systems and Control Encyclopedia. Ed. M.G.Singh. V.1-8. Pergamon Press, 1987.
- [3] The Control Handbook. Ed. W.S. Levine. CDC. Press. IEEE Press, 1996.
- [4] W. Harmon Ray. Advanced Process Control. McGraw-Hill, 1981.
- [5] Tanenbaum, A. S., Steen, M. V. (2006). Distributed systems: principles and paradigms, US Ed Edition ISBN-13: 978-1530281756. p: 60

SUPPLEMENTARY

*The Feedback Control Model*

The core of a feedback control system is formed by the components that are assumed to be driven through controllable input parameters, but their behavior may be influenced by all kinds of uncontrollable input (disturbance or noise input) (Fig. 1). The disturbance may, often come from the environment in which a distributed system is executing, and that unanticipated component interaction causes unexpected behavior. There are basically three elements that form the feedback control loop. First, the system itself needs to be monitored, which requires that various aspects of the system need to be measured. Second part of the feedback control loop analyzes the measurements and compares these to reference values. This feedback analysis component forms the heart of the control loop, as it contains the algorithms that decide on possible adaptations. The third part of components consists of various mechanisms to directly influence the behavior of the system.




Fig. 1 The logical organization of a feedback control system [5]