

# Thermodynamic Performance of Regenerative Organic Rankine Cycles

Kyoung Hoon Kim<sup>1</sup>

**Abstract**—ORC (Organic Rankine Cycle) has potential of reducing consumption of fossil fuels and has many favorable characteristics to exploit low-temperature heat sources. In this work thermodynamic performance of ORC with regeneration is comparatively assessed for various working fluids. Special attention is paid to the effects of system parameters such as the turbine inlet pressure on the characteristics of the system such as net work production, heat input, volumetric flow rate per 1 MW of net work and quality of the working fluid at turbine exit as well as thermal efficiency. Results show that for a given source the thermal efficiency generally increases with increasing of the turbine inlet pressure however has optimal condition for working fluids of low critical pressure such as iso-pentane or n-pentane.

**Keywords**—low-grade energy source, organic Rankine cycle (ORC), regeneration, Patel-Teja equation.

## I. INTRODUCTION

SINCE it is impossible to converse low grade energy to electricity efficiently by conventional methods, most of the low grade energy are just discarded. Therefore the research is important how to generate electricity efficiently from low grade energy sources. In recent years, organic Rankine cycle has become a field of intense research and appears as a promising technology for conversion of heat into useful work of electricity. In an ORC the saturation vapor curve is the most crucial characteristics of a working fluid. This characteristic affects the fluid applicability, cycle efficiency, and arrangement of associated equipment in a power generation system [1-2].

Schuster et al [3] mention numerous running applications, such as geothermal power plant, biomass fired combined heat and power plants, solar desalination plants, waste heat recovery or micro CHP. Drescher and Bruggemann [4] investigate the ORC in solid biomass power and heat plants. They propose a method to find suitable thermodynamic fluids for ORCs in biomass plants and found that the family of alkylbenzenes showed the highest efficiency. Dai et al [5] use a generic optimization algorithm, identified isobutane and R236ea as efficient working fluids. Heberle and Brueggemann [6] investigate the combined heat and power generation for geothermal re-sources with series and parallel circuits of an ORC.

Tranche et al. [7] investigate comparatively the performance of solar organic Rankine cycle using various working fluids. Volume flow rate, mass flow rate, power ratio as well as thermal

efficiency are used for comparison. Hung et al. [8] examine Rankine cycles using organic fluids which are categorized into three groups of wet, dry and isentropic fluids. They point out that dry fluids have disadvantages of reduction of net work due to superheated vapor at turbine exit, and wet fluids of the moisture content at turbine inlet, so isentropic fluids are to be preferred. Kim [9] investigated comparatively the thermodynamic performance of ORC with superheater for various working fluids including wet, dry and isentropic fluids.

In this paper, the thermodynamic performance of ORC with regeneration is comparatively investigated for various working fluids. The various thermodynamic characteristics of the ORC such as enthalpy ratio, net work production, heat input and volume flow rate as well as thermal efficiency are investigated in terms of the parameters such as turbine inlet pressure.

## II. SYSTEM ANALYSIS

The system considered in this work consists of condenser, pump, turbine, regenerator, pre-heater, boiler, and super-heater and its schematic diagram is shown in Fig. 1. The working fluids considered in this work are nine fluids of NH<sub>3</sub> (ammonia), R134a, R22, iC<sub>4</sub>H<sub>10</sub> (iso-butane), R152, R143a, C<sub>4</sub>H<sub>10</sub> (butane), iC<sub>5</sub>H<sub>12</sub> (iso-pentane), nC<sub>5</sub>H<sub>12</sub> (normal pentane). In this work the thermodynamic properties of the working fluids are calculated by Patel-Teja equation of state [10-11]. The basic data of the fluids which are needed to calculate Patel-Teja equation are shown in TABLE 1, where M, T<sub>c</sub>, P<sub>c</sub> and ω are molecular weight, critical temperature, critical pressure, and eccentric factor, respectively [12]. The molecular weights of NH<sub>3</sub> and




Fig. 1 Schematic diagram of the system

<sup>1</sup> K. H. Kim is with Dept. Mech. Eng., Kumoh National Institute of Technology, 61 Daehakro, Gumi, Gyeongbuk 730-701, Korea (phone: 82-54-478-7292; fax: 82-54-478-7319; e-mail: khkim@kumoh.ac.kr).

TABLE I  
 BASIC DATA FOR THE WORKING FLUIDS

substance	M (kg/kmol)	T <sub>c</sub> (K)	P <sub>c</sub> (bar)	ω
NH <sub>3</sub>	17.031	405.65	112.78	0.252
R134a	102.031	380.00	36.90	0.239
R22	86.468	369.30	49.71	0.219
iC <sub>4</sub> H <sub>10</sub>	58.123	408.14	36.48	0.177
R152a	66.051	386.60	44.99	0.263
R143a	84.041	346.25	37.58	0.253
C <sub>4</sub> H <sub>10</sub>	58.123	425.18	37.97	0.199
iC <sub>5</sub> H <sub>12</sub>	72.150	462.43	33.81	0.228
nC <sub>5</sub> H <sub>12</sub>	72.150	469.65	33.69	0.249

iC<sub>4</sub>H<sub>10</sub> are small, and those of R123 and C<sub>8</sub>H<sub>12</sub> are large among the fluids. The critical temperatures of R143a and R22 are low and those of nC<sub>5</sub>H<sub>12</sub> and iC<sub>5</sub>H<sub>12</sub> are high. The critical pressures of nC<sub>5</sub>H<sub>12</sub> and iC<sub>5</sub>H<sub>12</sub> are low and those of NH<sub>3</sub> and R22 are high. The temperature-entropy diagrams for the fluids are shown in Fig. 2. It can be seen from the figure that iC<sub>4</sub>H<sub>10</sub>, C<sub>4</sub>H<sub>10</sub>, iC<sub>5</sub>H<sub>12</sub> and nC<sub>5</sub>H<sub>12</sub> belong to dry fluids, R134a and R143a to isentropic fluids, and NH<sub>3</sub>, R22 and R152a to wet fluids. Especially, latent heat of vaporization of NH<sub>3</sub> is much greater than the others so the whole temperature-entropy diagram for NH<sub>3</sub> is not shown in the figure. The temperature-volume diagrams of the fluids are shown in Fig.3. The volume of saturated vapor at a given temperature is large for nC<sub>5</sub>H<sub>12</sub> or iC<sub>5</sub>H<sub>12</sub>, and small for R143a or R22.

A low-grade sensible energy is supplied to the system and important assumptions used in this work are as follows.

- 1) The energy source is air at temperature of T<sub>S</sub>.
- 2) The working fluid leaves the condenser as saturated liquid at temperature of T<sub>L</sub>.
- 3) The evaporating temperature, T<sub>E</sub> is lower than the critical temperature of the fluid and the turbine inlet temperature becomes T<sub>S</sub> - ΔT<sub>H</sub> by the superheater.
- 4) The minimum temperature difference between the hot and cold streams in the regenerator is operated at a prescribed




Fig. 2 Temperature-entropy diagrams for the working fluids

pinch point, ΔT<sub>pp</sub>.

- 5) Pressure drop and heat loss of the systems are negligible.

At point 1, the fluid is saturated liquid at T<sub>L</sub> and the corresponding saturated pressure P<sub>L</sub> is the low pressure of the system. When the evaporating temperature is T<sub>E</sub>, the corresponding saturation pressure P<sub>H</sub> is the high pressure of the system. The thermodynamic properties at point 4 are determined with the temperature T<sub>H</sub> and the pressure P<sub>H</sub>. The thermodynamic properties at points 2 and 5 are determined with the isentropic efficiencies of pump and turbine, η<sub>p</sub> and η<sub>t</sub>, respectively.

As the heat exchange area of regenerator increases, the temperature difference between the hot and cold streams, T<sub>hot</sub> - T<sub>cold</sub>, decreases and finally reaches the prescribed limit of the pinch point, ΔT<sub>pp</sub>. Then the thermodynamic properties at 2 and 5 can be determined from following conditions.

$$P_2 = P_H \quad (1)$$

$$P_5 = P_L \quad (2)$$

$$h_5 - h_6 = h_3 - h_2 \quad (3)$$

$$\min(T_{hot} - T_{cold}) = \Delta T_{pp} \quad (4)$$

Then heat addition and net work per unit mass of a working fluid  $q_{in}$  and  $w_{net}$ , and thermal efficiency  $\eta_{th}$  are obtained as

$$q_{in} = h_4 - h_3 \quad (5)$$

$$w_{net} = w_t - w_p = (h_4 - h_5) - (h_2 - h_1) \quad (6)$$

$$\eta_{th} = w_{net} / q_{in} \quad (7)$$

where  $h$  denotes specific enthalpy and subscripts  $t$  and  $p$  denote turbine and pump, respectively.

In this work enthalpy ratio,  $x$ , is defined as




Fig. 3 Temperature-specific volume diagrams for the working fluids

TABLE II  
 BASIC CALCULATION CONDITIONS

symbol	Parameter	data	unit
$T_S$	source temperature	200	$^{\circ}\text{C}$
$T_L$	condensing temperature	20	$^{\circ}\text{C}$
$\Delta T_H$	temperature difference at source inlet	15	$^{\circ}\text{C}$
$\Delta T_{PP}$	pinch point	10	$^{\circ}\text{C}$
$\eta_p$	isentropic efficiency of pump	0.80	
$\eta_t$	isentropic efficiency of turbine source	0.80	air

$$x = \frac{h - h_f}{h_g - h_f} \quad (6)$$

where  $h_f$  and  $h_g$  denote the specific enthalpy of saturated liquid and vapor of the working fluid, respectively. So when  $0 \leq x \leq 1$ ,  $x$  is same as the quality of the fluid and the fluid is the mixture of saturated liquid and vapor. When  $x < 0$ , the fluid is a compressed liquid, and when  $x > 1$ , the fluid is a superheated vapor.

### III. RESULTS AND DISCUSSIONS

The system parameters used in this work are summarized in Table II. In this work the basic data for analysis are  $T_S = 200^{\circ}\text{C}$  and  $\Delta T_H = 15^{\circ}\text{C}$ , so the turbine inlet temperature in this work is fixed at  $T_H = T_S - \Delta T_H = 185^{\circ}\text{C}$ . Fig. 4 shows the effects of the turbine inlet pressure on the enthalpy ratio for various working fluids. It can be seen from the figure that the enthalpy ratio decreases as the turbine inlet pressure increases. Enthalpy ratio of R143a or R22 is relatively high, and that of  $\text{NH}_3$  or  $\text{nC}_5\text{H}_{12}$  is relatively low. On the other hand, since this work is limited to the subcritical range, the turbine inlet pressure is lower than the critical pressure of the fluid so that the phase transition from liquid of vapor exists.

Fig. 5 shows the effects of the turbine inlet pressure on the temperature difference of the regenerator which is the




Fig. 4 Enthalpy ratio at turbine exit as a function of the turbine inlet pressure for various working fluids




Fig. 5 Temperature difference of regenerator as a function of turbine inlet pressure

difference between the temperature at the exit of turbine and the temperature at the exit of pump. The figure shows that the temperature difference decreases as the turbine inlet pressure increases when the turbine inlet temperature is held at a constant value, since as the turbine inlet pressure increases, the enthalpy ratio at turbine inlet or exit decreases and consequently the temperature at the turbine exit decreases. For a fixed value of turbine inlet pressure, the temperature of R143a R22 is relatively high, whereas that of  $\text{nC}_5\text{H}_{12}$  or  $\text{iC}_5\text{H}_{12}$  is relatively low.

Fig. 6 shows the effects of the turbine inlet pressure on the heat input per unit mass of working fluid for various working fluids. The figure shows that for a fixed value of turbine inlet pressure the heat input generally increases with increasing of the turbine inlet pressure. However, it has an optimal value with respect to the turbine pressure for working fluids of low critical




Fig. 6 Heat input per unit mass of source as a function of the turbine inlet pressure for various working fluids




Fig. 7 Net work per unit mass of working fluid as a function of turbine inlet pressure for various working fluids

pressure such as iC<sub>5</sub>H<sub>12</sub> or nC<sub>5</sub>H<sub>12</sub>. Heat input of NH<sub>3</sub>, is much higher than that of other working fluids, whereas heat input of R143a or R22 is relatively low.

Fig. 7 shows the effects of the turbine inlet pressure on the net work per unit mass of fluid for various working fluids. The figure shows that the net work per unit mass of fluid generally increases as the turbine inlet pressure increases. Net work of NH<sub>3</sub> is much higher than those of other fluids in the range of high turbine inlet pressure, and net work of nC<sub>5</sub>H<sub>12</sub> or iC<sub>5</sub>H<sub>12</sub> is relatively high, and R22 or R143a is relatively low. In the case of nC<sub>5</sub>H<sub>12</sub> or iC<sub>5</sub>H<sub>12</sub>, there exists an optimal value of the net work with respect to the turbine inlet pressure.

Fig. 8 shows the effects of the turbine inlet pressure on the




Fig. 8 Thermal efficiency as a function of the turbine inlet pressure for various working fluids




Fig. 9 Volume flow rate of working fluid at turbine exit to produce 1 MW of electricity as a function of the turbine inlet pressure

thermal efficiency for various working fluids. The figure shows that the thermal efficiency generally increases with the turbine inlet. For a fixed value of turbine inlet pressure, thermal efficiency of nC<sub>4</sub>H<sub>10</sub> or iC<sub>5</sub>H<sub>12</sub> is relatively high, whereas that of R143a or NH<sub>3</sub> is relatively low.

Fig. 9 shows the effects of the turbine inlet pressure on the volume flow rate at the turbine exit to produce 1 MW of net work for various working fluids. It can be seen from the figure that the volume flow rate of a working fluid to produce the same amount of net work decreases as the turbine inlet pressure increases, and the decreasing rate of the flow rate are relatively high for NH<sub>3</sub>, R22 and R143a. Since the volume flow rate to produce a same amount of net work relates directly with the size or cost of the turbine, the volume flow rate may be an important fact for selection of a working fluid for a system.

#### IV. CONCLUSION

In this paper, the performance of organic Rankine cycle with regeneration has been thermodynamically analyzed. The main results are as follows:

- 1) As turbine inlet pressure increases for a fixed source temperature, net work per unit mass of working fluid or thermal efficiency generally increases, however, has an optimal value for working fluids which have low critical pressures.
- 2) The volume flow rate per 1 MW of net work would be a criterion for selection of working fluid, and its decreasing rate are relatively high for NH<sub>3</sub>, R22 and R143a.
- 3) There is no working fluid which is the best for every aspect of thermodynamic performance. Therefore, in order to select an optimal working fluid for a system, various thermodynamic properties should be synthetically and comparatively considered.

#### ACKNOWLEDGMENT

This research was supported by Basic Science Research Program through the National Research Foundation of Korea (NRF) funded by the Ministry of Education, Science and Technology (No. 2010-0007355).

#### REFERENCES

- [1] N. A. Lai, M. Wendland, and J. Fisher, "Working fluids for high temperature organic Rankine cycle," *Energy*, vol. 36, pp. 199-211, 2011.
- [2] T. C. Hung, T. Y. Shai, and S. K. Wang, "A review of organic Rankine cycles (ORCs) for the recovery of low-grade waste heat," *Energy*, vol. 22, pp. 661-667, 1997.
- [3] A. Schuster, S. Karellas, and H. Splithoff, "Energetic and economic investigation of innovative Organic Rankine Cycle applications," *App. Therm. Eng.*, vol. 29, pp. 1809-1817, 2008.
- [4] U. Drescher and D. Brueggemann, "Fluid selection for the organic Rankine cycle (ORC) in biomass power and heat plants," *App. Therm. Eng.*, vol. 27, pp. 223-228, 2007.
- [5] Y. Dai, J. Wang, and L. Gao, "Parametric optimization and comparative study of organic Rankine cycle (ORC) for low grade waste heat recovery," *Energy Convs. Mgmt.*, vol. 50, pp. 576-582, 2009.
- [6] F. Heberle and D. Brueggemann, "Exergy based fluid selection for a geothermal organic Rankine cycle for combined heat and power generation," *App. Therm. Eng.*, vol. 30, pp. 1326-1332, 2010.
- [7] B. F. Tchanche, G. Papadakis, and A. Frangoudakis, "Fluid selection for a low-temperature solar organic Rankine cycle," *App. Therm. Eng.* vol. 29, pp. 2468-2476, 2009.
- [8] T. C. Hung, S. K. Wang, C. H. Kuo, B. S. Pei, and K. F. Tsai, "A study of organic working fluids on system efficiency of an ORC using low-grade energy sources," *Energy*, vol. 35, pp. 1403-1411, 2010.
- [9] K. H. Kim, "Effects of superheating on thermodynamic performance of organic Rankine cycles," *WASET*, vol. 78, pp. 608-612, 2011.
- [10] T. Yang, G. J. Chen, and T. M. Guo, "Extension of the Wong- Sandler mixing rule to the three-parameter Patel-Teja equation of state: Application up to the near-critical region," *Chem. Eng. J.* vol. 67, pp. 27-36, 1997.
- [11] J. Gao, L. D. Li, Z. Y. Zhu, and S. G. Ru, "Vapor-liquid equilibria calculation for asymmetric systems using Patel-Teja equation of state with a new mixing rule," *Fluid Phase Equilibria*, vol. 224, pp. 213- 219, 2004.
- [12] C. L. Yaws, *Chemical properties handbook*, McGraw- Hill, 1999.