

A Concept of Rational Water Management at Local Utilities – The Use of RO for Water Supply and Wastewater Treatment/Reuse

N. Matveev, A. Pervov

Abstract—Local utilities often face problems of local industrial wastes, storm water disposal due to existing strict regulations. For many local industries, the problem of wastewater treatment and discharge into surface reservoirs can't be solved through the use of conventional biological treatment techniques. Current discharge standards require very strict removal of a number of impurities such as ammonia, nitrates, phosphate, etc. To reach this level of removal, expensive reagents and sorbents are used.

The modern concept of rational water resources management requires the development of new efficient techniques that provide wastewater treatment and reuse.

As RO membranes simultaneously reject all dissolved impurities such as BOD, TDS, ammonia, phosphates etc., they become very attractive for the direct treatment of wastewater without biological stage. To treat wastewater, specially designed membrane "open channel" modules are used that do not possess "dead areas" that cause fouling or require pretreatment. A solution to RO concentrate disposal problem is presented that consists of reducing of initial wastewater volume by 100 times. Concentrate is withdrawn from membrane unit as sludge moisture. The efficient use of membrane RO techniques is connected with a salt balance in water system. Thus, to provide high ecological efficiency of developed techniques, all components of water supply and wastewater discharge systems should be accounted for.

Keywords—Reverse osmosis, stormwater treatment, open-channel module, wastewater reuse.

I. INTRODUCTION: USING MEMBRANES TO TREAT WASTEWATER

At early stages of wastewater treatment with the use of membranes, the role of the membrane was limited to "supporting" expensive reagents and sorbents.

Meanwhile, high rejection qualities of membranes enable us to treat sewage directly without expensive reagents sorbents and biological treatment process to obtain high quality water. Such approach to use membranes substantially reduces costs and simplifies treatment techniques.

Biological treatment process does not provide required removal level for major contaminants to reclaim municipal effluents, thus RO desalination techniques could be successfully applied to post-treat biologically used

wastewater. The concept of converting wastewater into new, raw water supply for further treatment to potable standards is called "indirect potable reuse", and is in use in the U.S. since the 1970s.

Membranes demonstrate high rejection characteristics for different contaminants, the idea to use membranes [1], [2] and other techniques [3], [4] for direct treatment promise to significantly reduce costs and simplify treatment.

As it was already discussed, high rejection characteristics of RO membranes enable us to treat sewage directly and obtain high-quality water without application of biological processes. This approach to using membrane tools substantially reduces costs. However, the main disadvantages of commercially available RO facilities are attributed to high fouling propensities, high cost pretreatment requirements, and concentrate disposal problems.

To overcome these problems, a series of experimental investigations was performed to develop newly modified "open channel" modules that possess a limited scaling and fouling potential.

For a long time formation of colloidal fouling layers on RO membranes was attributed to hydrodynamic flow characteristics (such as cross-flow velocities, concentration polarization level etc.).

It was also reported that configuration of membrane channel and module also should be considered as decisive factor that influence fouling [7].

There are examples in water treatment practice that directly treat surface water with nanofiltration membranes without pretreatment [8], [9].

As reported [9], [10], the process efficiency and reliabilities attributed mainly to hydraulic flow conditions in the membrane channels that provide enough shear force for the particles not to foul the membrane. These conditions are provided by channel configuration (using tubular or capillary membranes), by high cross-flow velocities as well as through application of hydraulic flushes and chemical cleanings.

This paper presents results of research that was conducted to improve conventional spiral wound configuration to treat directly wastewater, the conclusion that membrane fouling is dependent not only on hydraulic factors but on channel configuration as well was claimed in publication as early as 1991 [4] and this led to re-evaluation of the layout of the spiral wound module.

The main disadvantages of spiral wound module are

N. Matveev, PhD Student is with the Moscow State University of Civil Engineering, Department of Water supply, 129337 Moscow, Russia (tel. +79653161210; e-mail: info@water-storm.com).

A. Pervov, Professor is with the Moscow State University of Civil Engineering, Department of Water supply, 129337 Moscow, Russia (tel. +74991833629; e-mail: ale-pervov@yandex.ru).

attributed to presence of separation spacer mesh in the feed channel as it traps fouling particles and increases flow resistance (Fig. 1). The places (spots) where mesh contacts membrane surface provide "dead areas" without cross-flow, thus resulting in high concentration increase at the membrane surface within this area. Concentration polarization increases and initiates formation of crystals and coagulation of colloids inside these "dead areas".




Fig. 1 Fouling and scaling: influence of space. Formation of crystals in dead areas: a) – formation of scale crystals; b) – particle trapping and fouling layer formation

Elimination of the mesh could help to develop new types of modules with decreased fouling potential. This idea was discussed by Richard Riddle [6] in a report devoted to the development of an open-channel spiral wound module. Modification of spiral wound module [5] is shown on Fig. 2 where the mesh is withdrawn from the channel by dividing it into ledges and so providing higher cross-flow velocities.




Fig. 2 Spiral wound module with open-channel configuration

As was presented in a number of publications [7], [8],

elimination of the spacer mesh from the feed channels of a spiral wound membrane configuration eliminates "dead regions" that provide scaling (crystal formation) and fouling conditions while also reducing the risk of particle "trapping" and the increase of associated dramatic flow resistance. Fouling control is achieved by providing sufficient cross-flow velocities, flushing, and cleanings.

RO membrane units can thus be used to efficiently treat wastewater and reuse it for technical and irrigation purposes. In a number of cases such as private housing and small enterprises it's reasonably possible to reduce tap water consumption and domestic water discharge in municipal sewer.

Introduction of a new "open channel" configuration offers a new perspective to escape fouling and to treat water with high fouling potential. Principles of development of a novel concept of wastewater treatment processes are developed, field-tested and introduced into practice.

Fig. 3 shows a schematic flow diagram of an RO unit developed for wastewater treatment and reuse in a residential home. Wastewater is taken directly from the sewer; feed water passes through Miller Pump (that mills large size impurities such as paper, etc.), and is then forwarded to the screen that is automatically flushed to remove foulants and direct them back into a drain. Wastewater is then treated by RO membranes. The foulants that are accumulated on membrane surface are periodically removed through application of membrane flushes. The membrane unit is operated in circulation mode that ensures high concentrate flow velocities that provide a "shear" effect to prevent sedimentation of suspended particles on membrane surface and membrane fouling. Product water can be used for technical purposes (plant watering, car washing, heating or cooling systems feed). The use RO unit provides reuse of 80-90% of domestic wastewater. Yet, the majority of utilities lack the legal permission to discharge RO concentrate. To evaluate developed measures to reduce concentrate flow and increase recoveries, a pilot testing program was implemented.

A new concept of direct wastewater treatment by RO is based on the following principles:

- using of membrane modules with an "open channel" enables us to avoid membrane fouling throughout their operation even with high suspended matter content in the feed water;
- membrane units are operated in the circulation mode with high cross flow velocities that provide the "shear effect" of adhered foulants;
- fouling control is achieved by providing sufficient cross flow velocities, flushes and cleanings; – accumulated on membrane surface are withdrawn from membrane module during membrane flushes. Suspended matter after membrane flushes is collected, sedimented and finally dewatered.
- the main principles of high recovery maintenance are ensured by concentration of feed water in circulation mode by 50-100 times by volume. Concentrate volume

constitutes no more than 0,5 – 1% of the initial feed water volume and is withdrawn from the system together with a wet sludge as a sludge humidity.

and colloidal particles, fulvic and humic compounds that form water color that adsorb at coagulated particle surfaces.




Fig. 3 Reverse Osmosis unit to treat municipal wastewater a) pilot testing at the basement of the building; b) general view; c) flow diagram 1- main sewer; 2- milling pump; 3 - backwashed screen mesh; 4 – feed water pressurized tank; 5- pressure pump; 6 - solenoid valve at the inlet; 7 -membrane modules; 8- pressure gauge; 9 - product water pressurized tank; 10 - solenoid valves for flushing; 11 - pressurized flushing tank; 12 -pressure relay; 13- check valve; 14- flow counter

In a number of cases (private housing, small community, local enterprise) it seems very efficient to decrease tap water consumption and domestic wastewater discharge into municipal sewer.

The problem of concentrate disposal is the main problem that prevents successful industrial application of reverse osmosis and nanofiltration facilities to produce quality drinking and technical water. The solution of this problem in respect to development of new membrane systems to treat surface and well water and utilize concentrate is presented below. As it will be also shown in this article below, efficient use of membranes to treat wastewater and their successful concentrate utilization is closely connected with the efficient use of RO systems to produce low TDS drinking water that further becomes wastewater.

Fig. 4 shows the flow diagram of RO process to treat surface water to remove turbidity and color. The membrane unit is operated in circulation mode and recovery could reach 90-95 % value. Water after flushes is collected in a special sedimentation tank. After suspended matter contained in the flush water is sedimented, water is blended with the feedwater. The sedimented sludge is further dewatered. Thus, the sedimented sludge contains all main impurities that should have been removed from the feed water, such as suspended




Fig. 4 Flow diagram of RO process to treat surface water for removal of turbidity and color 1 – open channel module; 2 – recirculation pump; 3 – flush water tank; 4 – water for reuse; 5 – water reuse pump; 6 – circulation valve; 7 –solenoid valve; 8 – pressure gauge

Fig. 5 shows a flow diagram of the process described above where concentrate flow is treated by a nanofiltration membrane before it is blended with the product water. This treatment aims to reject excessive TOC, suspended solids, color, hardness and bacteria from the concentrate. We use low rejection nanofiltration membranes that poorly reject monovalent ions (by 40-50%) that provide NF product water TDS only 23-30% lower than the feed water TDS. The determined values of main water ingredients and ionic species in the feed water, product water and concentrate flows are presented in Table I.




Fig. 5 Flow diagram of RO process with concentrate treated by nanofiltration 1 – pump; 2 – RO membrane module; 3 – nanofiltration second stage membrane; 4 – bypass valve; 5,6 – solenoid valves for flushing; 7 – pressure gauges; 8 – sludge dewatering system; 9 – flush water sedimentation tank; 10 – water reuse tank; 11 – water reuse pump




Fig. 6 Flow diagram with calculated values of flows and TDS 1 – first stage RO module; 2 – second stage nanofiltration module; 3 – flush water sedimentation tank; 4 – sludge dewatering system

The values of oxidity, TOC, turbidity, color, suspended solids concentration are determined experimentally during pilot testing [7]. Fig. 6 shows the calculated balance of flows and TDS values of concentrate and product water. Balance calculations accounted for the amount of salts that entered the test unit and was withdrawn from it with the product flow (both first stage product flow and second stage NF product flow) and with dewatered sludge as sludge turbidity. It was also accounted that NF product water does not withdraw all

salts contained in RO first stage concentrate. To reach salt "equilibrium", the second stage NF unit is designed to provide higher product flow than first RO stage concentrate flow. The NF membrane second stage unit isoperated periodically using first stage RO concentrate as feed water collected in flushing tank (8). Its operation is controlled by the float switch concentrate. The amount of salts containing RO first stage concentrate that enters flush tank (8) thus equals to the amount of salts in second stage NF product water and sludge.

The described approach can be applied only for the cases when feed water contains only impurities that could be easily removed by sedimentation, such as: colloidal and suspended matter, colloidal iron, color, etc. When excessive hardness, fluoride, ammonia, pesticides etc. is contained, other techniques are utilized: only a part of concentrate is blended with product flow that provides optimal concentrations of rejected impurities. The remaining part of the concentrate flow could be further concentrated and withdrawn with the wet sludge as sludge humidity. The amount of water in the wet sludge constitutes about 0.8-1% of the feed water amount.

TABLE I
CHEMICAL COMPOSITIONS OF FEEDWATER, PRODUCT WATER AND CONCENTRATE


№		CHEMICAL COMPOSITIONS OF FEEDWATER, PRODUCT WATER AND CONCENTRATE									
		Feed surface water (River Desna)		1 st stage RO				2 nd stage RO			
		mEq/L	ppm	Product flow recovery 75%		Concentrate flow (recovery 75%)		Product flow (recovery 93,75%)		Concentrate flow (recovery 93,75%)	
		mEq/L	ppm	mEq/L	ppm	mEq/L	ppm	mEq/L	ppm	mEq/L	ppm
1	Calcium	3.8	76	1.7	34	9.5	190	5.3	106	22	440
2	Sodium	+	27.6	0.9	10.8	6.5	78	3.6	43.2	15	180
3	Sodium	5.7	131.1	2.6	59.8	13.6	312.8	1.81	41.63	9.2	211.6
4	Chlorides	2.1	73.5	1.4	49	4.2	147	2.8	98	8,4	294
5	Sulfate	0.8	38.4	0.1	4.8	2.9	139.2	1.25	60	7,8	374.4
6	Bicarbonate	5.9	359.9	3.7	225.7	12.5	762.5	6.66	406.26	30	1830
7	pH	6.85		6.75		7.6		7.3		8	
8	Oxidity	6.48			3.0		108		90		141
9	Color	4.2		17.5			368		164		911
10	Turbidity		12.1		0.1		145				
11	TDS	635.9		384.1			1629.5		775.09		3330
12	Flow %	100		75			25		18.75		16.25

As an example of an RO unit with decreased concentrate discharge, a membrane system with product water capacity of 15 cu. m per hour to remove fluoride and strontium from the well water is shown in Figs. 7-9. A low concentrate flow value is reached through the use of membrane modules on the second stage to further decrease concentrate flow. The process flow diagram is shown in Fig. 7. Fig. 4 (b) shows a membrane unit (one line) that produces 5 cubic meters per hour of product water. The 20 cm per hour unit consists of four 5 cubic meter lines connected in parallel. Feedwater is pumped into nanofiltration modules (in the first stage) where it is separated into product flow (15 cubic meters per hour) and first stage concentrate flow (5 cubic meters per hour). First stage product flow is forwarded to the product water tank and first stage concentrate enters the second stage nanofiltration

modules where it is further concentrated and separated into second stage product water (4 cubic meter per hour) and second stage concentrate (1 cubic meter per hour). The second stage product is added to the feedwater and concentrate is discharged into the sewer. Table I shows feedwater, product water and concentrate chemical compositions. A mass balance flow diagram of the described process is presented in Fig. 8, Fig. 9 (a) shows a water treatment station that includes a well water intake pavilion, a membrane unit located in a container, and the product water tank. The interior of the container is shown in Fig. 6 (b).



(a)



(b)

Fig. 7 Membrane system with a reduced concentrate disposal: a – photograph of one block, 5 cubic m per hour; b – flow diagram; 1 – 100 micron prefilter; 2- solid state antiscalant cartridge; 3- centrifugal pump; 4 – membrane module; 5 –second stage membrane module for concentrate flow reduction; 6- pressure relay; 7 – solenoid valve ; 8 - manometer; 9- product water counter; 10 – conductivity meter sensor; 11- concentrate flow meter; 12 – bypass flow meter; 13 – concentrate flowmeter; 14 - pressure gauges




Fig. 8 Flow diagram of membrane unit producing 15 cu. m per hour, showing flow and TDS values



(a)

(b)

Fig. 9 Water treatment station mounted inside the container: (a) – interior of the container; (b) – outside view of container attached to water intake

Calcium carbonate scaling hazard is recognized as a main factor that disturbs multiplied concentration of the feed water in membrane modules. The use of "open-channel" modules enables us to concentrate solutions that are supersaturated by calcium carbonate and calcium sulphate, and to develop a reagent-free technique to remove calcium carbonate water.

The present report aims to investigate the possibilities of decreasing concentrate discharge (to increase recovery) and reducing pretreatment expenses mainly connected with the use of chemicals and facilities to initiate flocculation and to predict calcium precipitation. To increase recovery values, a new process is developed that uses continuous crystallization of calcium carbonate at a constant supersaturation level provided by a constant raise of concentrate TDS while RO is operated in circulation mode.

Contamination of water sources by oil products and detergents is considered as a serious environmental problem. Car washes and gas stations are mainly responsible for pollution with oil products.

Conventional treatment facilities (based on coagulation - sedimentation - filtration techniques) do not always remove contaminants to a level that meets modern discharge regulation standards. These techniques require high operational costs to reuse sorption filter beds as their sorption abilities are rapidly exhausted. Membrane applications (RO and NF) provide efficient removal of organic and inorganic compounds that ensure high water quality sufficient to reuse it for different industrial purposes. The developed membrane units tailored with "open channel" modules provide separation of wastewater into two streams: purified water and wet sludge that contains suspended matter and dissolved oil, detergents and other impurities.

The use of local membrane systems can radically change a concept of storm water treatment. All storm water collected after rainfall should not be treated for oil and detergent removal. Storm water can be collected and treated by RO in the "sources" of contamination, such as gas stations, parking lots, oil and gas storage tanks. For most storm water, conventional sedimentation and filtration facilities can be used that do not have high operational costs.

Storm water is treated by a double stage RO membrane unit [11], shown on Fig. 10. A flow diagram of membrane units to treat storm water and car wash effluents is shown on Fig. 5. Concentrate flow is decreased by 50-100 times and is withdrawn from the system together with wet sludge as a sludge moisture. At car washes, an equilibrium is reached between the amount of salt that enters the system with cleaning water and the amount of salt that is contained in the sludge that is removed from the system. To determine required membrane characteristics and optimum operational parameters, a test program was undertaken.



(a)



(b)

Fig. 10 Double stage RO membrane unit for wastewater treatment, 6 cubic meter per hour capacity: (a) photo of the unit, general view; (b) operation of the membrane unit at local storm water treatment facilities




Fig. 11 Schematic flow diagram of storm water treatment: 1 - wastewater well pump; 2 - float switch; 3 -sedimentation tank; 4 - accumulation tank; 5 - pretreatment screen ;6 -pressure pump; 7 - membrane modules; 8- cleaning tank; solenoid valve; 9 - product water tank

II. EXPERIMENTAL PROCEDURE AND PILOT TEST PROGRAM

A pilot unit was designed to ensure high increase of concentration values of all wastewater impurities and dissolved salts using a double stage concentration. The field-

testing program was aimed at evaluation of membrane characteristics, recovery values and operational parameters for certain wastewater conditions.

The volume of water in the sludge does not exceed 1 % of the initial wastewater volume. Thus, membrane plant should not only purify wastewater and remove oil, TDS, BOD, etc., but also to reduce concentrate flow by 100 times (as compared to initial feed water flow). The second stage is used to reduce energy costs while concentrating dissolved salts and organics that increase osmotic pressure. Concentrate of the first stage (constituting about 20% of the initial flow) enters the second stage "tailored" with nanofiltration membranes. Product flow of the second stage is mixed with feed water. The pilot unit contains sedimentation tanks, concentration tanks and membrane flushing systems.

Fig. 12 (a) shows the developed pilot plant producing 300 liters per hour for purification of domestic wastewater and concentrate utilization. The pilot plant was installed and successfully operated at wastewater treatment facilities that treat domestic wastewater of a Gas Pumping station - an Enterprise that belongs to Gasprom (Russia). The ecological situation at the enterprise location at the agricultural district does not permit to discharge even biologically treated and post treated water basing on strict requirements of phosphate, ammonia , sodium and chloride concentrations (Table II). In certain cases where ammonia removal requirements are very strict, double stage RO can be applied (Table II).




Fig. 12 Membrane pilot plant for wastewater treatment and concentrate utilization: a) 300 liter per hour membrane pilot plant; b) pilot testing at municipal wastewater facilities

TABLE II
 WASTEWATER COMPOSITION DURING DIFFERENT PURIFICATION STAGES

Index	Feed waste-water	First RO stage product	Second stage product	RO product	Regulation permitted discharge
Suspended solids mg/L	124	0.2	0	0.5	7.6
pH	7.9	7.1	6.3	7.3	6.5-7.5
NH ₄ ⁺ , mg/L	12.8	0.43	< 0.05	0.21	0.189
NO ₃ , mg/L	-	-	-	0.62	7.44
NO ₂ , mg/L	-	-	-	0.17	0.0075
PO ₄ , mg/L	2.44	0.1	0	0.07	0.401
COD, mg/L	190	32	8.8	24	-
SO ₄ , mg/L	71	3.8	0.25	3.7	-
Cl, mg/L	142	14.1	1.6	15	-
TDS mg/L	738	72	8.3	71	-

The location of the pilot unit at the wastewater treatment facilities is shown in Fig. 13 (b). Schematic flow diagram of the pilot unit is shown in Fig. 14. The unit is developed to demonstrate possibilities of reducing concentrate flow to 1% of the initial feed water volume, and all wastewater impurities could be discharged together with wet sludge as sludge turbidity.

The field testing program was aimed at evaluation of membrane characteristics, recovery values, and operational parameters for certain wastewater conditions.




Fig. 13 Flow diagram of membrane pilot plant to treat wastewater with 99% concentrate recovery: 1 – feed water flow meters; 2 - solenoid valve at the inlet; 3 - pressure gauge; 4 – feed water tank; 5 – feed water concentration tank; 6 - level censor; 7 - first RO stage pump; 8 - pressure tank for flushing; 9 - check valve; 10 - first stage RO module; 11- first stage RO concentrate pressure gauge ; 12 - first stage flushing solenoid valve; 13 - first stage RO bypass valve; 14 - first stage product water flow meter; 15 - manometer; 16 - first stage concentrate collection tank; 17 - second stage RO concentrate tank; 18 - second stage feed pump; 19 - second stage RO pressure pump; 20 - second stage RO membrane module; 21 - second stage membrane flushing solenoid valve; 22 - second stage concentrate pressure gauge; 23 - second stage bypass valve; 24 - second stage concentrate flow meter; 25 - tank level control; 26 - low level control; 27 - sediment withdrawal valve; 28 - valves; 29 - sampling valves; 30 – solenoid valve controller

The double stage RO pilot unit was developed to study possibilities of purifying wastewater for its further reuse. The design and equipment used in the unit (flow diagram, membrane modules and pumps) enable us to develop required operational modes (such as membrane rejection and product quality, recovery, pressure values) depending on the feed wastewater quality. Reverse osmosis membranes reject dissolved ionic species (ammonia, nitrates, phosphates) and organics (derived as BOD). RO membranes used at the first stage of RO pilot unit remove all required impurities from wastewater to meet standards for effluents discharged into surface water sources. The use of a second stage tailored with nanofiltration (or low pressure RO membranes) reduces

concentrate flow by 100 times or greater without additional power costs. Product water after second stage membranes is mixed with the feed water.

Initial wastewater flow after the second stage is reduced by 100 times and has TDS value 25,000 -30,000 ppm. To maintain the second stage membrane unit permeability on the 6-8 liter/ hour sq. meter level, working pressure of 14-15 Bar is applied.

The flow diagram of the test unit is presented in Fig. 13. The initial water flow (storm water, car washing water) enters the inlet feed water sedimentation tank (4) and is poured into the feed water concentration tank (5). After the tank (5) is filled, a float tank level control switch closes the solenoid valve (2) at the initial water inlet. The initial water flow is regulated by a pressure gauge (2) at the inlet and controlled by a water flow meter (1).

Wastewater from the tank (5) is pumped by a centrifugal pump Speroni RSM-5 (pressure 6-8 Bar) to the first stage membrane modules. Two membrane spiral wound modules are used on the first stage of 4040 standard, (TFC BLN membrane, supplied by CSM, Korea). The first stage product water can be used (reused) for technical purposes or discharged. Pressure value in the first stage membrane modules is maintained on 6-8 Bar level and controlled by pressure gauge (11) and manometer (15).

To maintain a cross-flow mode, concentrate flow after first RO stage is returned back to tank (4) using by-pass valve (13). A part of the first stage concentrate (10-20%) enters first stage concentrate collection tank (16), which is also used at the second stage inlet. To remove colloidal and suspended particles that are sedimented on the membrane surface, hydraulic flushes are applied. The flushing procedure consists of opening the solenoid valve (12) and discharging the first stage concentrate. When the solenoid valve (12) opens, the pressure drops and the increased flow "flushes" foulants off the membrane surface and discharges them into the sedimentation tank (4). To increase the flush flow value, a pressure tank (8) is used.

The second stage unit is used to further decrease the RO concentrate volume. Concentrate from the second stage RO concentrate tank (17) is pumped into the membrane nanofiltration module (20). The module of 4040 standard uses 70 NE membranes (CSM, Korea). To provide pressure value of 14-15 Bars, two Speroni RSM-5 pumps were used (one-by-one). The second stage pressure value is controlled by a pressure gauge (22) and manometer (15). When the test unit is started-up, a certain time is required to reach stable operation characteristics (concentrate flow and TDS). While concentrate volume is reduced during membrane unit operation, membrane product flow (in the first and second stages) also decreases. Fig. 8 shows the increase of the first and second stage concentrate TDS and membrane product flow decrease with time during the start-up period.

Product water after the second stage is returned to the feed water tank (4), Fig. 13. The smallest part of concentrate (1% of initial water flow) is discharged from the unit together with

sedimented sludge for further dewatering. Other concentrate is returned to the tank (16) through bypass valve (23).

The sedimented sludge, which is removed from membrane surface during flushing, is withdrawn from tanks (4) and (16) using valves (27).




Fig. 14 Variations of membrane performance with time and during recovery increase and concentrate utilization: a) Concentrate TDS growth; b) Product flow decrease; c) Product TDS growth 1 – BLN membrane (CSM); 2 – 90 NE membrane (CSM); 3 – 70 NE membrane (CSM).

First stage product water and second stage concentrate flows are controlled by flow meters (14) and (24). To control concentrate and product water quality, sampling valves (29) are used.

Accumulated foulant is withdrawn from the second stage membrane surface by applying flushes that consist of opening the solenoid valve (21). Automatic mode uses float switches (25) and (26). First stage pump (7) stops when tank (17) is full and when tank (5) is empty using tank level control switch (25). The second stage pumps (18) and (19) are stopped using tank level control switch (26) when tank (17) is empty. Signal from monitor (30) opens the Solenoid valves (12) and (21) using time relays. The duration of each flush and the flush schedules are programmed depending on wastewater composition and operational mode.

In our pilot experiments, flushes were organized after two-three hours of constant operation, flush duration was 10-20 seconds.

To reach maximum ecological efficiency, the developed RO process should account for local conditions when applied for wastewater reuse. The efficient solution of wastewater reuse for local utilities suggests an application of membrane units for boiler feed and drinking water production. This statement has a following explanation. Table III and Fig. 14 data show that concentrate flow for the certain conditions depends on wastewater TDS. When low pressure RO and NF membranes are applied, it is reasonable to operate the test unit when concentrate TDS does not exceed 25000 - 30000 ppm.

Membrane flux becomes very low under these conditions. To reach higher recoveries, higher pressure is required that needs different membrane and pumping equipment as well as higher power consumption. The lower the initial TDS value, the higher the recovery value that can be reached (Table III).

TABLE III
 THE INFLUENCE OF WASTEWATER SALINITY ON RO RECOVERY

Index	Wastewater salt content, mg/L				
	800	400	200	100	50
Feed water consumption, m ³ /day	100	100	100	100	100
Product TDS, mg/L	40	20	10	5-6	3-5
Wastewater concentrate flow (discharged as sludge humidity), m ³ /day	3.8*	1.9*	0.9	0.48	0.24
Wastewater concentrate TDS mg/L	20 000	20 000	20 000	20 000	20 000

*Further recovery increase can be achieved by using additional nanofiltration membranes

Therefore, to decrease concentrate flow (i.e. to increase recovery), feed water TDS should be reduced. To reduce municipal wastewater TDS, RO membrane units can be used to produce drinking water. Municipal wastewater TDS is also very dependent on the amount of ion exchange water softeners (and their effluents) used for boiler feed and drinking water production for the certain utilities. Application of local RO membrane units for boiler feed and drinking water production could significantly decrease wastewater TDS. For the use of developed "open channel" membrane modules, the principles of RO concentrate utilization are described in previous publications [4].

Membrane treatment efficiencies to remove oil products, detergents, to reduce BOD and TDS under described RO operation conditions (with concentrate volume decreased by 99%) were investigated. Tables IV and V show membrane treatment efficiencies in separating storm water and car wash effluent depending on product recovery values. A test program was undertaken to investigate rejection of membranes versus recovery values. A flow diagram of the test unit is shown on Fig. 15.




Fig. 15 (a, b) Double stage RO membrane unit for laboratory tests: (a) photo; (b) flow diagram 1 – feed water tank; 2 - membrane module; 3 - product water tank; 4 - pressure pump; 5 - tap of sampling; 6 - product water; 7 - RO concentrate; 8 – feed water; 9 – product water; 10 - manometer

TABLE IV
CONCENTRATION VALUES OF DIFFERENT WATER, PRODUCT AND
CONCENTRATE THROUGHOUT STORMWATER TREATMENT

	Normal	Feed wastewater	Average RO product	Second stage product	Second RO concentrate	P x90	C x90
Suspended solids mg/L	3	23,8	0,39	0,29	34,0	3,4	119
BOD, mg/L	3	7,24	4,7	4,0	177,0	43,8	784
Cl, mg/L	-	266,0	-	-	568,0	795	5822
Fe, mg/L	0,1	1,72	0,106	0,169	2,3	0,044	6,2
Oil, mg/L	0,05	0,55	<0,01	0,06	1,27	0,188	10,1
TOC, mg/L	-	0,494	0,046	0,232	0,292	0,054	1,86
TDS, mg/L	1000	465	363	50	1280	2700	12150

TABLE V
CONCENTRATION OF OIL, DETERGENTS, BOD IN PRODUCT WATER AND
CONCENTRATE OF RO SYSTEM DURING CAR WASH TREATMENT

	Feed waste water	Average RO product	First stage product	RO product	First RO concentrate	P x20	C x20
Suspended solids mg/L	49,6	<0,10	<0,10	80,2	<0,10	186,0	
BOD, mg/L	65,7	2,84	3,81	164,0	16,0	275,0	
Oil, mg/L	4,19	0,081	<0,001	6,0	0,372	13,4	
TOC, mg/L	0,262	0,001	0,008	0,048	0,013	0,753	
TDS, mg/L	774	53,2	21	972	306	8910	

Results of tests are illustrated in Figs. 16-20. Fig. 16 shows the drop of membrane flux with recovery increase throughout test run.

When recovery reaches 0,9-0,95 value, product flow decreases by 2,5 -3 times. Further recovery increase requires application of second stage membranes operated under higher pressure value. Fig. 17 demonstrates relationships of BOD, detergents and oil concentration values in product water on recovery. Reverse osmosis efficiencies can be represented by C/Creq ratio value as a function of recovery, where C is concentration value of the certain impurity in product water and Creq is its required concentration value in product water discharged into surface water source according to existing regulations. Fig. 18 shows dependencies of C/Creq ratios on recovery. The growth of feed water salinity (TDS) decreases membrane rejection characteristics. Fig. 19 shows results of experiments aimed at investigation of feed water TDS influence on oil concentration behavior in the product water after treatment of car wash wastewater with different salinities. With TDS growth concentrations of oil in the product water also increase.

Fig. 20 shows results of experimental data processing to predict efficiencies of oil removal depending on feed water salinity and recovery. Extrapolation of the obtained curves

provides dependencies of oil concentration in product water on recovery that corresponds to required TDS level in the feed water.




Fig. 16 Dependence of C/Creq value on concentration factor and recovery values 1 - Creq. (required value of contaminant concentration); 2 - BOD; 3 - detergents; 4 - oil products




Fig. 17 Increase of oil, detergents, BOD and TDS in product water versus recovery and concentration factor throughout test run. a) - detergents; b) - TDS; c) -oil products; d) - BOD




Fig. 18 Reduction of product flow with TDS growth during storm water treatment by double stage RO




Fig. 19 Dependencies of oil concentrations in product water a) and oil rejection b) on concentration factor and recovery 1 - feed water (storm water); 2 - storm water with addition of sodium chloride, 3000 ppm; 3 - storm water with addition of sodium chloride, 6000 ppm




Fig. 20 Oil concentrations in product water versus recovery and concentration factor for different TDS values of feed water. Feed water TDS: 1 - 1500 ppm; 2 - 774 ppm; 3 - 300 ppm

The obtained results are used to determine RO operational conditions: membrane type, required recovery, pressure etc.

III. RESULTS AND DISCUSSIONS. PRINCIPLES OF RATIONAL WATER MANAGEMENT IN LOCAL UTILITIES. USING DEVELOPED RO TECHNIQUES

The modern concept of rational water resources management requires the development of new and efficient techniques for the treatment and reuse of wastewater. The authors developed an approach to solve the problem of environmental pollution.

This approach results in the development of local water management programs. The efficiency of the RO techniques depends on wastewater salinity. The data presented in Fig. 8 and Table I indicate that the efficiency of RO (the possibility of reducing concentrate flow to 1%) is dependent on the feed water TDS. To reduce wastewater TDS, RO membrane units should be used to produce potable water (that ultimately goes to the sewer) and to produce boiler feed water for heating systems (replacing ion exchange softeners conventionally used for water softening) to avoid discharge of regeneration solutions to the sewer. The purified wastewater can be used for garden irrigation, washing cars, and to feed cooling/heating systems. Storm water that contains oil and surfactants is also purified by similar RO techniques. This treatment and concentrate utilization is facilitated by low TDS of storm water.

To decrease groundwater consumption and wastewater discharge, wastewater effluents can be treated by a local RO plant to provide quality technical water that can be reused for boiler feed, car washing, plant watering. To reduce concentrate flow value, membrane RO units should be also used for drinking water production. Membrane units produce water with decreased TDS, iron and hardness concentrations. Therefore, total TDS of wastewater can be significantly reduced through the use of RO, and concentrate discharge could be minimized. With the average unit water consumption value assumed at 200-250 liter per person daily, wastewater after shower and toilet use increased TDS by only 40-50 ppm. If supplied water has TDS value of 100 ppm or less, this water could be easily treated by RO and RO concentrate could be easily utilized and discharged as sludge humidity. Figs. 21 and 22 shows water flow distribution: a flow diagram of water supply and wastewater treatment facilities developed for a small utility of 200-300 residents.

There is no place to discharge wastewater, and the suggested techniques enable to completely reuse it for local industrial needs such as: boiler feed, heating, cooling, plant watering.

Membrane facilities tailored with "open channel" modules can be used for multi-purpose needs as they can treat wastewater and well water. Thus, local water utilities can use the same RO unit for technical water production (for boiler feed, heating and cooling) using both well water source and collected storm water.

This provides an efficient return of investment in storm water treatment and reuse.

A strategy of local utilities water management is developed that is based on the use of membrane facilities both for water supply and wastewater treatment/reuse. Membrane units provide efficient product water quality when treating both municipal and storm water to purify and reuse it for technical purposes: for boiler feed and heating, for cooling systems and garden pouring.

To reduce the amount of wet sludge discharge, wastewater ionic composition should also be controlled using RO to produce low TDS product water for drinking and domestic needs.

To facilitate treatment of wastewater, small size local membrane units are used at the points where "sources of contamination" are detected: ion exchange regeneration solution discharges, storm water collected from car parking lots, gas stations and gas storage tanks.




Fig. 21 A balance flow diagrams of water supply and wastewater treatment at a local utility: existing scheme (a) and proposed scheme using membrane techniques (b) 1 - water treatment plant (a - iron removal; b -RO plant); 2 - facilities buildings; 3 - compressor pump station; 4 - boilers; 5 - car washing ground; 6 - plant watering station; 7 - wastewater treatment plant; 8 - sludge beds ; 9 – storm water treatment and car washing effluents treatment station




Fig. 22 Flow diagram of membrane techniques used for drinking water production, wastewater treatment and reuse 1 – well pump; 2 – well water pressure tank; 3 – membrane unit pump; 4 – membrane modules; 5 – product water pressure tank; 6 – pressure gauges; 7 – wastewater collection tank; 8 – wastewater feed pump; 9 – first stage RO concentrate sedimentation tank; 10 – first stage RO pressure pump; 11 – first stage RO membrane modules; 12 – first stage RO pressure tank; 13 – second stage RO pump; 14 – second stage RO membrane modules; 15 – second stage RO pressure tank; 16 – second stage RO concentrate sedimentation tank; 17 – concentrate flow reduction unit pump; 18 – concentrate flow reduction unit membrane module; 19 – sludge disposal valve; 20 – septic tank; 21 – sludge bed

IV. CONCLUSIONS

To treat wastewater, specially designed membrane "open channel" modules are used that do not possess "dead areas" that cause fouling.

The main principles of high recovery maintenance are ensured by concentration of the feed water in circulation mode by 50-100 times by volume. Concentrate volume constitutes no more than 0,5-1% of the initial feed water volume and is withdrawn from the system together with a wet sludge as a sludge moisture.

The present report demonstrates the design of "integrated" water management using the developed RO systems for water supply and wastewater reuse as an example of advanced,

ecologically-safe water treatment. Local utilities and privately-held industrial sites are encouraged to reuse wastewater and reduce freshwater intake, thereby promoting rational water management and reducing environmental pollution.

REFERENCES

- [1] J. Losier, A. Fernandez, Using a membrane bioreactor/reverse osmosis system for indirect potable reuse, Proc. of the conf. on Membranes, Paris, October 2000, Desalination publications, L'Aquila, Italy. Vol. 2, 297-311.
- [2] O. Duin, P. Wessels et al., Direct nanofiltration or ultrafiltration at WWTP effluent. Proc. of the conf. on Membranes, Paris, October 2000, Desalination publications, L'Aquila, Italy. Vol. 2, 105-112.
- [3] M. Abdel-Javad, S. Ebrahmet. al., Advanced technologies for municipal wastewater purification: technical and economic assessment, Desalination, 124 (1999), 251-261.
- [4] Pervov A. Scale formation prognosis and cleaning procedure schedules in reverse osmosis operation, Desalination (1991), 83, 77-118.
- [5] Pervov A., Andrianov A. Application of membranes to treat wastewater for its recycling and reuse: new considerations to reduce fouling and increase recovery up to 99 per cent, Desalination and water treatment (2011) 35, 2-9.
- [6] R.A. Riddle. Open channel ultrafiltration for reverse osmosis pretreatment. IDA World Conference on Desalination and Water Reuse. August 25-29, 1991, Washington DC. Pretreatment and Fouling.
- [7] R. Bian, K. Yamamoto, Y. Watahabe. The effect of shear rate on controlling the concentration polarization and membrane fouling. Proceedings of the Conf. on Membranes in Drinking and Industrial Water Production, Paris, France, 3-6 October 2000, v.1, p. 421-432.
- [8] ITT PCI Membranes - Membrane Technology- tubular membranes - micro-, ultra-, nanofiltration, reverse osmosis, <http://www.pcimembranes.eu/> (accessed 7 November 2010).
- [9] H. Futselaar, H. Schoneville, W.Meer. Direct capillary nanofiltration for surface water. Desalination, 157 (2003), 135-136.
- [10] N. Matveev, A. Pervov. Use of reverse osmosis to treat domestic wastewater for local utilities and in small industries. Tianjin ida world congress 2013 on desalination and water reuse. IDAWC REF: TIAN13-217. 20-25 october, China, 2013.
- [11] A. Pervov, N. Matveev. Applications of Open Channel Membrane Modules to Treat and Reuse Wastewater. Journal of Membrane and Separation Technology | Volume 3 Number 1, 2014, 11-28. DOI: <http://dx.doi.org/10.6000/1929-6037.2014.03.01.2>