

Surge Analysis of Water Transmission Mains in Una, Himachal Pradesh (India)

Authors : Baldev Setia, Raj Rajeshwari, Maneesh Kumar

Abstract : Present paper is an analysis of water transmission mains failed due to surge analysis by using basic software known as Surge Analysis Program (SAP). It is a real time failure case study of a pipe laid in Una, Himachal Pradesh. The transmission main is a 13 kilometres long pipe with 7.9 kilometres as pumping main and 5.1 kilometres as gravitational main. The analysis deals with mainly pumping mains. The results are available in two text files. Besides, several files are prepared with specific view to obtain results in a graphical form. These results help to observe the pressure difference and surge occurrence at different locations along the pipe profile, which help to redesign the transmission main with different but suitable safety measures against possible surge. A technically viable and economically feasible design has been provided as per the relevant manual and standard code of practice.

Keywords : surge, water hammer, transmission mains, SAP 2000

Conference Title : ICCEAE 2014 : International Conference on Civil, Environmental and Architectural Engineering

Conference Location : Madrid, Spain

Conference Dates : March 27-28, 2014