

Using ALOHA Code to Evaluate CO₂ Concentration for Maanshan Nuclear Power Plant

Authors : W. S. Hsu, S. W. Chen, Y. T. Ku, Y. Chiang, J. R. Wang, J. H. Yang, C. Shih

Abstract : ALOHA code was used to calculate the concentration under the CO₂ storage burst condition for Maanshan nuclear power plant (NPP) in this study. Five main data are input into ALOHA code including location, building, chemical, atmospheric, and source data. The data from Final Safety Analysis Report (FSAR) and some reports were used in this study. The ALOHA results are compared with the failure criteria of R.G. 1.78 to confirm the habitability of control room. The result of comparison presents that the ALOHA result is below the R.G. 1.78 criteria. This implies that the habitability of control room can be maintained in this case. The sensitivity study for atmospheric parameters was performed in this study. The results show that the wind speed has the larger effect in the concentration calculation.

Keywords : PWR, ALOHA, habitability, Maanshan

Conference Title : ICLWRS 2018 : International Conference on Light Water Reactor Safety Analysis

Conference Location : Tokyo, Japan

Conference Dates : March 27-28, 2018